

# PUBLIC PRIVATE SCHOOL

## STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC PRIVATE SCHOOL INSPECTION REPORT



Geocoded 25.637064/-80.374879

**PURPOSE:**  
 ROUTINE  
 CONSTRUCT.  
 COMPLAINT  
 QA SURVEY  
 OTHER

REINSPECTION  
 CHANGE OF OWNER  
 CONSULTATION  
 EPIDEMIOLOGY  
 PREOPENING

**TYPE:** Public School

| CENSUS | FEMALES | MALES |
|--------|---------|-------|
| 1137   | 569     | 568   |

**NAME** Frank C. Martin K-8 Center  
**ADDRESS** 14250 Boggs Drive **CITY** Richmond Heights  
**OWNER** M-DCSB Food and Nutrition **ZIP** 33176  
**PERSON IN CHARGE** Felicia Joseph **PHONE** (305) 238-3688  
**E-MAIL** rhoel1@dadeschools.net

**RESULTS:**

Satisfactory  
 Incomplete  
 Unsatisfactory  
 OUT OF BUSINESS

Correct Violations by  
 Next Inspection  
 8:00 AM on

| BEGIN TIME | END TIME | DATE ASSESSED | POSITION # | EXISTING FACILITIES - PERMIT NUMBER |
|------------|----------|---------------|------------|-------------------------------------|
| 10:45      | 11:45    | 09/22/2014    | 82515      | 13-51-08257                         |

| RE-INSPECTION DATE |
|--------------------|
|                    |

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**SCHOOL SANITATION**

- 1. School Site
- 2. Playground Equipment
- 3. Athletic Equipment

**SANITARY FACILITIES**

- 8. Natural Ventilation
- 9. Mechanical Ventilation
- 10. Provided/Accessible
- 11. Cleanliness & Repair
- 12. Toilet Facilities
- 13. Separation of Sexes
- 14. Fixture Ratio

15. Handwash Facilities

- 16. Showers/Fixtures
- 17. Shower Water Temp.
- WATER SUPPLY**
- 18. Installed/Operated/Maintained
- 19. Drinking Fountains
- 20. Approved Source

**LIQUID/SOLID WASTE**

- 21. Sewage Disposal
- 22. Solid Waste
- VECTOR/VERMIN CONTROL**
- 23. Infestation/Control
- 24. Brush/Trash
- 25. Water Collection/Drainage

**SAFETY**

- 26. First Aid Kit
- FOOD**
- 27. Food Insp. Rpt.
- OTHER**
- 28.
- 29.

**BUILDINGS**

- 4. Construction
- 5. Maintenance & Repair
- 6. Lighting/Foot-Candles
- 7. Heating, Ventilation, A/C

**COMMENTS AND INSTRUCTIONS**

**Violation #15** Provide missing soap dispenser in bathrooms 016,919,960 and 815. Provide soap in bathrooms 960 and 961. Provide paper towel in restrooms 920,961,108,815 and 816. Repair hand dryer machine in bathroom 108.  
**Code Reference** FAC: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited. Hot-air hand drying devices

**Violation #19** Clean/replace mouth piece for drinking water fountain located near to classroom #4 and the other one in front of the staff lounge 508.  
**Code Reference** FAC: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

INSPECTION CONDUCTED BY: Maria Adrover PHONE: (305) 623-3500 ex.  
 INSPECTION COND SIGNATURE: [Signature] PHONE: (305) 623-3500 ex.  
 COPY OF REPORT RECEIVED BY: [Signature] DATE: 9/22/2014

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY PUBLIC HEALTH UNIT  
Public/Private School



Name: Frank C. Martin K-8 Center

Date: 09/22/2014

Identification No: 13-51-08257

Comments and Instructions (Continued from Page 1):

Copy of Report  
Received By:

Inspector Maria Adrover

Page 2